

Pujariput, Medical Road
Koraput
Dist :Koraput Pin 764002

sudhirkumardash@gmail.com
sudhirkumardash@rediffmail.com
sudhirkumardash@yahoo.com
M-9937662924, M-7008142640

Letter No SC /16

Date 25.03.2022

Structural Stability Certificate

- This is to certify that the building plan of RamaKrushnaSatsanga ,at Housing Board colony is estimated for two storied structure over the Plot No.83 ,Khata No 126,atHousing Board colony,Koraput, Mauza -Kumbha 1,Ward no.3, Tahsil – Koraput of District-Koraput, Odisha and is designed for two storied structure, as per I.S.456/ 2000 and I.S 875 /1978 and the foundation is designed with composit structure of R.C.C.framed structure and masonry wall for bearing the loads as per I.S 875/1978.The foundation and column footing of the building is designed for safe structure and checked taking shear and stress parameters in to account . The safe bearing capacity of the soil below 1.75 mt depth is 180 Kg/Cm² which is pretty good and the zone is not within the Earth Quack zone nor within flood affected area and the life presumed to be Thirty years.
- Sri Amulya Ranjan Mohapatra ,S/O LateMurali Mohan Mohapatra for Rama KrushnaSatsanga take responsibility for the safe construction and safety for the building and action may be taken if the plan, design submited contain misrepresenation or fraudulent statement of the fact and construction failure and fire endangering to the inmates and the public.
-

for STRUCTURAL ENGINEERING CONSULTANCY

25/3/2022

Er. S.K. Dash(A.M.I.E) Civil
M.Tech (Structures)
M.B.A (HR & Finance)
Chartered Engineer (India)
M.B.A (M.B.A. Finance)
Chartered Engineer (India)
(Autoged, STADD, M.S. Project, Primavera, REV1)
S/o Structural Engineer (P.M.C)

Permanent Address

Signature for Rama KrushnaSatsanga
Sri Amulya Ranjan Mohapatra
S/O LateMurali Mohan Mohapatra



ପୌର ପରିଷଦ, କୋରାପୁଟ

KORAPUT MUNICIPALITY

No. 5925 / 2021

Date: 06/12/2021

TO WHOM IT MAY CONCERNED

Certified that, as per documents submitted by the Principal, Sri Ramkrushana Vidya Mandir, Koraput and report of the Assistant Engineer of this Municipality, the building of Sri Ramakrushana Vidya Mandir, Koraput is safty for 450 students.

06/12/2021
Assistant Engineer,
Koraput Municipality

06/12/2021
Executive Officer,
Koraput Municipality.

Memo No. 5926 /2021

Date: 06/12/2021

Copy to the Principal, Sri Ramakrushana Vidya Mandir, Koraput for information and necessary action with reference to her letter No.47/SRKVM Dt.06.12.2021.

06/12/2021
Executive Officer,
Koraput Municipality.